

TYPE CERTIFICATE

No. 4124010047B

Type: Phase Sequence Indicator

PHQ

Technical specifications

*	Measuring voltage:	380440V AC ±20% three phase
*	Measuring frequency:	4565Hz
	Galvanic separation:	Input to front: 3,25kV
	Temperature:	-1055°C (nominal)
		-2560oC (operating)
		-2565oC (storage)

Type Test specifications Tested according to:

Vibration:	313,2Hz: ±1mm peak	DNV Class A
	13,2100Hz: 0,7g	IACS UR E10
Safety:	3,25kV, 50Hz, 1 minute	EN 61010-1, EN 60529
EMC:	Imminity	EN 61000-6-1/2
	Emission	EN 61000-6-3/4

^{*)} Tested on all units according to specifications. Ramaining specifications are tested regularly by test sampling

Martin S. Mallan Type Test Manager

May Mah

Ref.: MSM Date: 19th January 2011

