



TYPE APPROVAL CERTIFICATE

Certificate No:
TAA00000ZM
Revision No:
1

This is to certify:

That the **Position Controller**

with type designation(s)
EPQ96-2

Issued to

DEIF A/S
Skive, Midtjylland, Denmark

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Temperature	B
Humidity	B
Vibration	A
EMC	A
Enclosure	See page 2

Issued at **Høvik** on **2022-02-02**

This Certificate is valid until **2027-01-09**.

DNV local station: **Denmark CMC**

Approval Engineer: **Ståle Sneen**



for **DNV**
Digitally Signed By: **Sjåvåg, Trond**
Location: **DNV Høvik, Norway**

Trond Sjåvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 3



Job Id: 262.1-021128-2
Certificate No: TAA00000ZM
Revision No: 1

Product description

EPQ96-2 electronic potentiometer

Digitally controlled electronic unit intended for control of electronic speed governors. The unit converts relay output from a PI controller to a control voltage/current, or PWM signal as input for the electronic speed governor.

Technical data

Output Voltage:	0...±10 VDC. Output impedance 500 Ω
Output Current:	0...±20 mADC. Resistive load max 500 Ω
Integrating time (2 settings):	2.5...25 s or 12.5...125 s
Resolution/ response time:	2.5 mV or 5 µA RMS/ < 0.1 s
PWM output:	0...6 VDC 500 Hz ±50 Hz
PWM output:	Low level 0...0.05 V; High level 5.7...6 V
PWM resolution/ response time:	10 000 steps/ <0.1 s

Digital output contact:	AUTO/MAN (Auto mode when closed)
Digital output contact:	STATUS OK (OK when contact closed)

DEIF application notes 4189340149 Rev.O to be observed

Protection:	IP52 (panel front), IP20 (panel rear)
Aux. voltage:	12...24 VDC
Pollution degree:	2 (anti-condensation heating required)

Place of manufacture

DEIF A/S
7800 Skive
DENMARK

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings



Job Id: 262.1-021128-2
Certificate No: TAA00000ZM
Revision No: 1

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE