



中国船级社
CHINA CLASSIFICATION SOCIETY

证书编号/Certificate No.
GB25PTB00023

型式认可证书
CERTIFICATE OF TYPE APPROVAL

兹证明本证书所述制造厂具备按照下列标准的要求生产本证书所列产品的能力和条件。

This is to certify that the manufacturer stated in the certificate meets the requirements of the standards listed below and is available with the ability and conditions to produce the products described in the certificate.

制造厂/Manufacturer

DEIF A/S

地址/Address

Frisenborgvej 33, DK-7800 Skive, DENMARK

产品名称/Product

智能控制器
Intelligent controller

认可标准/Approval Standard

1. 中国船级社《钢质海船入级规范》第4篇第1、2、3章
Chapter 1&2&3, Part Four of China Classification Society Rules for Classification of Sea-Going Steel Ships
2. 中国船级社《钢质海船入级规范》第7篇第2章
Chapter 2, Part Seven of China Classification Society Rules for Classification of Sea-going Steel Ships
3. 中国船级社《船舶网络安全指南》(GD14-2024)
China Classification Society Guidelines For Ship Cyber Security (GD014-2024)
4. IACS UR E27 (Rev.1) Cyber resilience of on-board systems and equipment

用于/Intended for

船舶与海上设施/Ships and Offshore Installations
the Power Management System



证书有效期至/This Certificate is valid until 2029年08月25日/ Aug. 25,2029

发证机构 中国船级社哥本哈根办事处
Issued by CCS Copenhagen Office

签发日期 2025年10月26日
Date Oct. 26,2025

本证书根据中国船级社规范和相关规定签发。所有证书页为一个整体，必须同时使用。纸质证书每页均须由本社盖章方为有效，电子证书含数字签名方为有效，本证书复印件无效。任何单位和个人均不应摘录或节选本证书的部分内容。有关方对所持证书的真实性有疑问时，可以向本社检验机构咨询。本证书凡是未注明版本的规范，其（发证时）最新版本适用于本证书。
This Certificate is issued pursuant to the Rules of the Society and related regulation. All pages of the certificate are taken as a whole and are used simultaneously. No paper certificate page is valid without bearing the stamp of the Society, no electronic certificates is valid without the digital signature, and no copied form of the certificate is regarded as valid. Any part of the certificate is not to be extracted or abridged by any unit or individual in any form. Related parties who are doubted about the authenticity of the certificate may inquire of the Society or its offices. **For Rules with no version indication, their latest version (at the time of issuance of the certificate) applies to the certificate.**



Form No: T01.

联系方式/Contact Us, 见本社官方网站/See official web site of the Society (<http://www.ccs.org.cn>)

UTN:P025-11406087

产品明细/Product Description

电站控制和保护用多功能系统/Multi-Function System for Control and Protection of Generator Plant (M0001)

名称/Name	属性(值)/Value	单位/Unit
型号/Type	iE 350 Marine, iE 350 PLC See additional page for details	

批准的图纸/Approved Drawings

图纸批准号/ Drawings Approval No. : NP25PPP02385

产品认可试验报告/ Approval Test Report

试验报告编号/ Test Report No. : 929 iE350 A tests
试验报告日期/ Test Report Date : 2024-05-31
试验单位/ Laboratory: DEIF A/S
试验单位地址/ Test Address: Frisenborgvej 33, DK-7800 Skive, DENMARK

试验报告编号/ Test Report No. : 929 iE350 B tests
试验报告日期/ Test Report Date : 2024-05-24
试验单位/ Laboratory: DEIF A/S
试验单位地址/ Test Address: Frisenborgvej 33, DK-7800 Skive, DENMARK

试验报告编号/ Test Report No. : EPC 929-05_20_A_FAT iE350 Marine
试验报告日期/ Test Report Date : 2024-05-27
试验单位/ Laboratory: DEIF A/S
试验单位地址/ Test Address: Frisenborgvej 33, DK-7800 Skive, DENMARK

试验报告编号/ Test Report No. : EPC 929-05_21_A_FAT iE350 Marine Power Management
试验报告日期/ Test Report Date : 2024-05-28
试验单位/ Laboratory: DEIF A/S
试验单位地址/ Test Address: Frisenborgvej 33, DK-7800 Skive, DENMARK

试验报告编号/ Test Report No. : ie350_e27_testreport
试验报告日期/ Test Report Date : 2025-09-30
试验单位/ Laboratory: DEIF A/S
试验单位地址/ Test Address: Frisenborgvej 33, Skive, 7800, Denmark

认可后的产品检验方式/ Method of Product Inspection after Approval

按规范只认可不进行产品检验的产品/The product approved only in term of the rules:
认可后的产品由制造厂检验合格后签发合格证明, 并连同该产品的本社认可证书复印件一并交付用户, 制造厂对产品符合公约、法规、本社规范和本社认可的标准规定负责。
After approval, product inspection should be carried out by the Manufacturer. Upon satisfactory inspection, and the Quality Certificate issued by the Manufacturer should be provided to the purchaser together with the copy of the approval certificate issued by the Society. The manufacturer should take responsibility for the product being in compliance with the convention, statutory regulation, the Society rules and the standard accepted by the Society.

认可保持条件/ Maintenance Requirements of Approval

1. 型式认可后, 如果产品及其重要零部件的设计、所用材料或制造方法有所改变, 且影响到产品的主要特性、特征; 或产品的性能指标有所更改, 且超过认可的范围, 则有关图纸和文件应经检验机构审批。并在检验机构认为必要时, 经本社检验人员见证有关试验和进行检查, 其结果应能证实仍符合认可条件。
After type approval, if there are changes to the design, materials used or manufacturing method of the product and important components and such changes affect major characteristics and properties of the product, or property indexes of the product are changed and exceed the scope of approval, related drawings and documents are to be examined and approved by the concerned survey office. Where deemed necessary by the survey office, the surveyor to the Society will go to witness relevant tests and conduct inspection and the results should be able to demonstrate compliance with the approval conditions.
2. 工厂的质量管理体系应保持有效运行, 并且与认可时一致。如果质量管理体系发生改变, 应经原体系认证机构审核并报本社批准。

The quality management system of the factory shall be ensure effective operation, and shall be the same as the situation of approval. If there are any changes to the quality management system, auditing of the original certification organization for quality management system and the society's approval shall be obtained.

3. 认可证书有效期内, 如果出现可能导致本社取消认可的情况, 工厂应及时采取有效的纠正措施。

Within the validity of the approval certificate, if cases occur that may cause the Society to withdraw the approval, the manufacturer should take corrective actions in a prompt and effective manner.

4. 在认可证书有效期内, 本社检验人员可在未经事先通知的情况下对工厂的产品制造过程进行审核, 以验证产品的生产是否符合业经本社批准的图纸和文件。工厂应予以配合。

Within the validity of the approval certificate, the surveyor to the Society may pay unannounced audit to the manufacturing process of the product in order to confirm whether it is in compliance with the drawings and documents approved by the Society. The factory should provide an active cooperation and necessary for the surveyor.

5. 证书获得者应接受本社每年一次的定期审核, 定期审核日为认可证书期满之日对应的每一周年日, 检查工作应在周年日的前后三个月内进行。

Those who have obtained the certificate should be subject to periodical audit every year. The date of periodical audit shall be each anniversary date which corresponds to the date of expiry of the relevant certificate and the periodical audit shall be done within a time span of three months before and after the annual surveillance date.

备注/Remarks

1. 本社已审核了产品厂无石棉声明, 但本社的审核不免除产品厂按照合同关系向订货方保证产品无石棉的责任。

The declaration of asbestos-free submitted by manufacturer has been reviewed by the Society. However, liability of the manufacturer to guarantee the products are asbestos-free to purchaser under contract will not be exempted.

2. 本证书基于原型式认可证书 (No. GB24PTB00043) 变更, 原证书保持有效。

This Certificate is modified from the previous Type Approval Certificate No. GB24PTB00043, the previous certificate remains valid.

3. 本系统业经上述认可依据中的网络韧性SLO级别验证, 系统可满足IACS UR E27 Rev.1。

The approved system was verified in accordance with cyber resilience level SLO, as defined by the approval standards above, and the requirements of IACS UR E27 Rev.1 are fulfilled.

4. 结合具体项目申请本社检验时 (或向系统集成商交付产品时), 以下文件应提交批准: CBS资产清单、网络系统拓扑图、配置核查报告/When the product is delivered to the system integrator, the following documentation of the specific base individual application is to be submitted for approval in each case:

- CBS asset inventory
- Topology diagrams
- Test report for configuration of security capabilities.

5. 本产品不支持直接与不可信网络连接, 不支持无线访问, 本系统硬件以及访问界面应设置在受控物理区域/

This product does not support direct connection to untrusted networks and does not support wireless access. all hardware devices and accessible interfaces in the CBS shall be installed in areas with physical access restrictions.

6. 如实际产品交付时重大变化 (含硬件及软件) 应通知CCS, 若变化明显影响本社相关要求时, 可能需要进行型式试验, 签发新的认可证书。/ Major changes of the type approved system affecting future deliveries shall be informed to CCS. If the changes are considered to affect functionality for which rule requirements apply, a new functional type test may be required, and the certificate may have to be renewed to identify the new version.

7. 工厂应确保产品的开发遵循安全开发生命周期中各阶段的网络安全要求, 编制相应的程序和安全更新文件应持续有效, 并符合本社《船舶网络安全指南》及IACS UR E27要求。/The manufacturer shall ensure that the development of products meets the cyber security requirements at each stage of Secure Development Lifecycle, and develop corresponding procedures and security update documents that are continuously effective and comply with CCS "Guidelines for Ship Cyber Security" and IACS UR E27 requirements.

中国船级社哥德堡办事处

CCS Gothenburg Office

注: 本证书含有附页, 共2页

Note: The certificate is attached with additional 2 page(s)

Description of Product

The iE 350 is a versatile, modular-designed controller, and the supported features depend on the installed software licence.

It includes the following hardware building blocks:

-Processor and communication module PCM3.3	Software: iE 350 PLC Application: C/C++ and CODESYS application Interface: 5x Ethernet (1 independent, 4 switched (managed)), 4 x CAN, 2x RS-422/485 (1x RS-232), 1x USB Host, 1 x Display Port Processor: 1.6 GHz quad core Memory: 2 GB DDR4 RAM 128 kB FRAM Storage: 32 GB non-volatile (-8 GB user available)
-Power supply module PSM3.1 and PSM3.2	Power supply: 12 or 24 V DC nominal (8 to 36 V DC continuously)
-Alternating current modules ACM3.1	2 direct 3-phase AC voltage measurements 3-phase AC current measurement 4th current measurement
-Differential current module ACM3.2	3-phase AC current measurement - Consumer side 3-phase AC current measurement - Neutral side
-Input output modules: IOM3.1	4 changeover relay outputs 10 digital inputs
-Input output modules: IOM3.2	4 relay outputs 4 analogue multifunctional outputs 4 digital inputs
-Input output modules: IOM3.3	10 analogue multifunctional inputs
-Input output modules: IOM3.4	16 digital inputs 12 digital outputs
-Governor and AVR module GAM3.1 and GAM3.2	
-Engine interface module EIM3.1	
-Display unit iE7	• IP65 (front of module when installed into the control panel with the supplied sealing gasket) • IP20 on terminal side

It can be used as the iE350 Marine/Marine PM by installing the following software:

Software	Version
Operating System	BSP 5.0.x.x
Controller Application	2.0.x.x
REST Version	1.0.x.x
CODESYS version	1.3.x.x
HMI Web Config Version	1.0.x.x
HMI Display WebUI	1.0.x.x

It provides the following functions with the Core Licence:

- + Breaker trip and alarms
- + Synchronization check
- + Breaker close (external command)
- + Breaker position detection
- + Breaker open and close (external command)
- + Synchronization (dynamic and static) and deloading
- + Diesel generator start and stop commands
- + Load sharing (isochronous, over DEIF Ethernet ring network)

Additional functions are available with the Power Management Licence:

- + Load-dependent start and stop of generators
- + Generators priority selection
- + Automatic blackout recovery
- + Heavy consumer function
- + Stop of non-connected generator

It can also be used as the iE350 PLC by installing the following software:

Software	Version
Operating System	BSP 5.0.x.x
PLC Application	2.0.x.x
REST Version	1.0.x.x
CODESYS version	1.3.x.x
HMI Web Config Version	1.0.x.x
HMI Display WebUI	1.0.x.x